

No: 41.01.09/2604.Dec.2014

Petrobangla
Production & Marketing Division
 3, Kawran Bazar, Dhaka-1215

Date : 17-18 Dec, 2018

From 8.00 to 8.00

 Units:
 Gas in MMCFD
 Condensate/ NGL/ MS/ HSD in BBLD
 LPG in Ka

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Capacity | Production | | Pro. as a % of T.Cap(Gas) | Pro. as a % of T. Prod(Gas) |
|------------------|----------------------------|------------------------|----------|------------|------------|---------------------------|-----------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFL | Titas | 26 | 542 | 476.1 | 421.0 | 14.6 | 16.7 |
| | Habiganj | 7 | 225 | 225.4 | 22.0 | 6.9 | 1.0 |
| | Bakhrabad | 6 | 43 | 29.3 | 18.0 | 0.9 | 0.9 |
| | Narsingdi | 2 | 30 | 26.0 | 42.5 | 0.8 | 0.9 |
| | Meghna | 1 | 11 | 12.0 | 20.2 | 0.4 | 0.4 |
| | Sub-Total | 42 | 851 | 768.8 | 523.7 | 23.6 | 27.0 |
| 2. SGFL | Sylhet | 1 | 6 | 4.5 | 32.3 | 0.1 | 0.2 |
| | Kailashitla #1 (Silicagel) | 1 | 13 | 8.0 | 48.1 | 0.2 | 0.3 |
| | Kailashitla #2 (MSTE) | 3 | 55 | 61.2 | 514.8 | 1.9 | 2.1 |
| | Rashidpur | 5 | 60 | 51.2 | 39.2 | 1.6 | 1.8 |
| | Beanibazar | 2 | 15 | 8.8 | 136.5 | 0.3 | 0.3 |
| | | Sub-Total | 12 | 149 | 133.7 | 772.9 | 4.1 |
| 3. BAPEX | Salda | 1 | 3 | 4.4 | 0.5 | 0.1 | 0.2 |
| | Fenchuganj | 2 | 26 | 11.3 | 3.8 | 0.3 | 0.4 |
| | Shahbazpur | 3 | 50 | 47.2 | 5.6 | 1.4 | 1.7 |
| | Semutung | 2 | 3 | 0.5 | 0.0 | 0.0 | 0.0 |
| | Sundalpur | 1 | 5 | 6.5 | 0.3 | 0.2 | 0.2 |
| | Srikail | 3 | 40 | 35.6 | 103.9 | 1.1 | 1.2 |
| | Begumganj | 2 | 10 | 6.5 | 1.9 | 0.2 | 0.2 |
| | Rupganj | 0 | 8 | 0.0 | 0.0 | 0.0 | 0.0 |
| | | Sub-Total | 14 | 145 | 112.1 | 115.8 | 3.4 |
| | Sub-Total (1+2+3) | 68 | 1145 | 1014.6 | 1412.3 | 31.1 | 35.6 |
| 4. IOCs | Jalalabad | 7 | 270 | 242.2 | 1016.4 | 7.4 | 8.5 |
| | CHEVRON Maulavibazar | 6 | 42 | 17.6 | 1.1 | 0.5 | 0.6 |
| | Bibiyana | 26 | 1200 | 1216.6 | 8757.3 | 37.3 | 42.7 |
| | TULLOW Bangora | 5 | 103 | 99.2 | 302.0 | 3.0 | 3.5 |
| | Sub-Total | 44 | 1615 | 1575.7 | 10076.8 | 48.3 | 55.3 |
| 5. RPGCL (R-LNG) | | | 500 | 257.6 | | 7.9 | 9.0 |
| | | | 0 | 500 | 257.6 | 0.0 | 7.9 |
| | Sub-Total | | 500 | 257.6 | | 7.9 | 9.0 |
| | Grand Total (1+2+3+4+5) | 112 | 3260 | 2847.8 | 11489.1 | 87.4 | 100.0 |

III. RPGCL Production

| Feed Received | Production | | | |
|---------------|------------|-------|-------|--------|
| | NGL | Cond. | LPG | MS HSD |
| 610.1 | 0.0 | 23831 | 696.7 | 433.3 |

 N-S & RA pipeline
 Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 0.0 |
| AB2 | 221.8 |
| BB | 250.7 |
| VS3 | 130.9 |
| AM | 479.5 |
| BD | 510.2 |
| Total | 1593.2 |

Remarks:

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|-------------------------|-----------------------------|--------|------------------------------------------|------------|--------------|-------|---------|
| | Demand | Supply | Company | Max.Demand | | | |
| TGTDCL | Ghorashal (1315 MW) | 148.0 | 73.5 | JFCL | 45.0 | 0.6 | 1198.8 |
| | Max (G)-78 MW Rent | 20.0 | 13.3 | UFFL | 45.0 | 6.7 | |
| | Aggreko (GSL)-145 MW Rent | 38.0 | 0.0 | PUFF | 14.0 | 10.6 | |
| | Siddhirganj (210 MW) | 30.0 | 0.0 | | | | |
| | Siddhirganj (2x120 MW) | 52.0 | 36.3 | | | | |
| | HPS (100 MW) | 16.0 | 0.0 | | | | |
| | EGCB 412 MW | 68.0 | 52.3 | | | | |
| | Meghnaghat IPP 450 MW | 75.0 | 66.2 | | | | |
| | Tongi (80 MW) | 26.0 | 0.0 | | | | |
| | RPCL (210 MW) | 40.0 | 32.7 | | | | |
| | Madhabdi (27+10 MW) REB | 9.0 | 6.2 | | | | |
| | Ashulia (24+10 MW) REB | 10.0 | 5.4 | | | | |
| | Doreen Tangail 22 MW SIPP | 5.0 | 2.4 | | | | |
| | Doreen Narsingdi 22 MW SIPP | 5.0 | 1.8 | | | | |
| | Maona 33 MW SIPP | 8.0 | 6.2 | | | | |
| | Rupganj 33 MW SIPP | 8.0 | 4.2 | | | | |
| | EGCB Shiddhirganj 335 MW | 55.0 | 29.0 | | | | |
| EGCB HPL 360 MW | 55.0 | 52.4 | | | | | |
| Regent 108 MW | 27.0 | 14.5 | | | | | |
| | Sub-Total | 695.0 | 396.3 | | 104.0 | 17.9 | 1198.8 |
| BGDCL | Ashuganj 648 MW* | | 56.3 | AFCL | 52.0 | 50.4 | 95.6 |
| | Ashuganj 55 MW rental | 192.0 | 0.0 | | | | |
| | Ashuganj 53 MW rental | 20.0 | 0.0 | | | | |
| | Ashuganj -80 MW Rent | 40.0 | 34.6 | | | | |
| | Ashuganj 225MW | 40.0 | 2.0 | | | | |
| | APS 450 MW CCPP S | 62.0 | 48.2 | | | | |
| | APS 450 MW CCPP N | 62.0 | 54.8 | | | | |
| | B-bania 70 MW rental | 24.0 | 9.7 | | | | |
| | Feni-22 MW SIPP | 5.0 | 4.7 | | | | |
| | Mohipal-11 MW SIPP | 3.0 | 1.6 | | | | |
| | Jangalia-33 MW SIPP | 8.0 | 1.3 | | | | |
| | Chandpur 150 MW CCPP | 27.0 | 24.6 | | | | |
| | Cornilla REB 24 MW | 6.0 | 3.9 | | | | |
| Midland Power 51 MW | 12.0 | 3.3 | | | | | |
| | Sub-Total | 501.0 | 245.0 | | 52.0 | 50.4 | 95.6 |
| KGDCL | Raozan (2x210) MW | 95.0 | 48.6 | CUFL | 52.0 | 45.9 | 2.1 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCO | 63.0 | 48.9 | 168.4 |
| | Sikalbaha (225+150+65) MW | 73.0 | 0.0 | | | | |
| | Barabkunda 22 MW SIPP | 5.0 | 4.3 | | | | |
| | Sub-Total | 185.0 | 52.9 | | 115.0 | 94.8 | 170.5 |
| JGTDCL | Shahjibazar 2x30 MW | 18.0 | 17.4 | SFF | 45.0 | 36.6 | 81.0 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 8.2 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 7.1 | | | | |
| | S.Bazar 330 MW | 47.0 | 48.2 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 13.8 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 13.5 | | | | |
| | Kumargaon 20 MW | 2.0 | 0.0 | | | | |
| | K.gaon 3 yrs rent 50 MW | 12.0 | 4.8 | | | | |
| | K.gaon 15 yrs rent 10 MW | 3.0 | 0.2 | | | | |
| | K gaon 142 MW CCPP | 36.0 | 27.4 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 1.6 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 3.2 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 2.9 | | | | |
| | Shahjahanullah pgcl Rent | 5.0 | 3.7 | | | | |
| | Bibiyana-2 341 MW | 50.0 | 0.0 | | | | |
| | Bibiyana-3 400 MW | 40.0 | 0.0 | | | | |
| | Khushiyara 163 MW | 28.0 | 23.9 | | | | |
| | Sub-Total | 334.0 | 175.9 | | 45.0 | 36.6 | 81.0 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 29.4 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 4.2 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 1.3 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 1.2 | | | | |
| | NWPGCL Unit-1 | 38.0 | 0.0 | | | | |
| | NWPGCL Unit -2 | 38.0 | 31.7 | | | | |
| | NWPGCL Unit -3 | 38.0 | 0.0 | | | | |
| NWPGCL Unit -4 | 70.0 | 0.0 | | | | | |
| | Sub-Total | 247.0 | 38.4 | | 0.0 | | 29.4 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 6.6 | | | | 1.4 |
| | Bhola 225 MW | 35.0 | 30.7 | | | | |
| | Bheramara 360MW | 65.0 | 56.1 | | | | |
| | Aggreko 95MW | 26.0 | 8.8 | | | | |
| | Sub-Total | 136.0 | 102.2 | | 0.0 | | 1.4 |
| | Total : | 2098.0 | 1010.7 | | 316.0 | 199.7 | 1576.6 |
| | | | 1783 (Considering diversity factor 0.85) | | | | 2787.0 |
| Non-grid power | | | | | | | |
| | TGTDCL | | 72.3 | | | | |
| | KGDCL | | 11.2 | | | | |
| | Total Non-Grid Power | | 83.4 | | | | 83.4 |
| | Grand Total | 2098.0 | 1094.1 | | 316.0 | 199.7 | 1576.6 |
| % of Total Distribution | | | 38.1 | | | 7.0 | 54.9 |
| | | | | | | | 100 |