

Units:

Gas in MMCFD  
Condensate/ NGL/ MS/ HSD in BBLD  
LPG in Kg

## Daily Gas &amp; Condensate Production and Distribution Report

## I. Production

| Company   | Gas Fields                   | No. of Producing Wells | Production Capacity | Production    |                | Pro. as a % of T.Cap(Gas) | Pro. as a % of T. Prod(Gas) |
|-----------|------------------------------|------------------------|---------------------|---------------|----------------|---------------------------|-----------------------------|
|           |                              |                        |                     | Gas           | Condensate     |                           |                             |
| 1. BGFCFL | Titas                        | 26                     | 542                 | 529.6         | 462.0          | 19.2                      | 19.9                        |
|           | Habiganj                     | 7                      | 225                 | 219.8         | 11.1           | 8.0                       | 1.2                         |
|           | Bakhrabad                    | 6                      | 43                  | 32.8          | 18.0           | 1.2                       | 1.0                         |
|           | Narsingdi                    | 2                      | 30                  | 27.2          | 42.6           | 1.0                       | 1.0                         |
|           | Meghna                       | 1                      | 11                  | 12.8          | 21.1           | 0.5                       | 0.5                         |
|           | <b>Sub-Total</b>             | <b>42</b>              | <b>851</b>          | <b>822.2</b>  | <b>554.8</b>   | <b>29.9</b>               | <b>30.8</b>                 |
| 2. SGFL   | Sylhet                       | 2                      | 8                   | 4.8           | 29.9           | 0.2                       | 0.2                         |
|           | Kailashtila #1 (Silicagel)   | 2                      | 13                  | 9.7           | 61.3           | 0.4                       | 0.4                         |
|           | Kailashtila #2 (MSTE)        | 3                      | 55                  | 53.5          | 433.9          | 1.9                       | 2.0                         |
|           | Rashidpur                    | 5                      | 60                  | 53.4          | 28.5           | 1.9                       | 2.0                         |
|           | Beanibazar                   | 2                      | 15                  | 9.2           | 145.2          | 0.3                       | 0.3                         |
|           | <b>Sub-Total</b>             | <b>14</b>              | <b>151</b>          | <b>130.6</b>  | <b>698.7</b>   | <b>4.7</b>                | <b>4.9</b>                  |
| 3. BAPEX  | Salda                        | 1                      | 10                  | 3.7           | 0.5            | 0.1                       | 0.1                         |
|           | Fenchuganj                   | 3                      | 26                  | 12.5          | 4.3            | 0.5                       | 0.5                         |
|           | Shahbazpur                   | 3                      | 50                  | 30.4          | 4.5            | 1.1                       | 1.1                         |
|           | Semutung                     | 2                      | 3                   | 1.6           | 0.8            | 0.1                       | 0.1                         |
|           | Sundalpur                    | 0                      | 0                   | 0.0           | 0.0            | 0.0                       | 0.0                         |
|           | Srikail                      | 3                      | 40                  | 36.7          | 103.1          | 1.3                       | 1.4                         |
|           | Begumganj                    | 0                      | 0                   | 0.0           | 0.0            | 0.0                       | 0.0                         |
| Rupganj   | 1                            | 8                      | 0.0                 | 0.0           | 0.0            | 0.0                       |                             |
|           | <b>Sub-Total</b>             | <b>13</b>              | <b>137</b>          | <b>84.9</b>   | <b>113.2</b>   | <b>3.1</b>                | <b>3.2</b>                  |
|           | <b>Sub-Total (1+2+3)</b>     | <b>69</b>              | <b>1139</b>         | <b>1037.6</b> | <b>1366.7</b>  | <b>37.7</b>               | <b>38.9</b>                 |
| 4. IOCs   | Jalalabad                    | 7                      | 270                 | 259.3         | 1216.6         | 9.4                       | 9.7                         |
|           | CHEVRON                      | 5                      | 42                  | 35.3          | 4.4            | 1.3                       | 1.3                         |
|           | Bibiyana                     | 26                     | 1200                | 1239.9        | 9364.4         | 45.0                      | 46.5                        |
|           | TULLOW                       | 5                      | 103                 | 94.4          | 285.0          | 3.4                       | 3.5                         |
|           | <b>Sub-Total</b>             | <b>43</b>              | <b>1615</b>         | <b>1629.0</b> | <b>10870.4</b> | <b>59.1</b>               | <b>61.1</b>                 |
|           | <b>Grand Total (1+2+3+4)</b> | <b>112</b>             | <b>2754</b>         | <b>2666.6</b> | <b>12237.1</b> | <b>96.8</b>               | <b>100.0</b>                |

## III. RPGL Production

| Feed Received |       | Production |       |       |
|---------------|-------|------------|-------|-------|
| NGL           | Cond. | LPG        | MS    | HSD   |
| 540.9         | 0.0   | 20491      | 916.2 | 202.3 |

N-S & RA pipeline  
Delivered from N-S pipeline

|              |               |
|--------------|---------------|
| AB1          | 220.4         |
| AB2          | 260.9         |
| BB           | 242.9         |
| VS3          | 125.9         |
| AM           | 458.0         |
| BD           | 404.4         |
| <b>Total</b> | <b>1712.5</b> |

Remarks:

## II. Distribution

| Company                  | Power                      |               | Fertilizer   |         | Others-Supl. | Total        | Remarks       |
|--------------------------|----------------------------|---------------|--------------|---------|--------------|--------------|---------------|
|                          | Power Plants               | Demand        | Supply       | Company |              |              |               |
| TGTDCCL                  | Ghorashal (598 MW)*        | 148.0         | 71.1         | JFCL    | 45.0         | 42.0         | 1257.6        |
|                          | Ghorashal-78 MW Rent       | 20.0          | 13.4         | UFFL    | 45.0         | 0.0          |               |
|                          | Ghorashal-145 MW Rent      | 38.0          | 25.3         | PUFF    | 14.0         | 0.0          |               |
|                          | Siddhirganj (190 MW)       | 30.0          | 27.8         |         |              |              |               |
|                          | Siddhirganj (105X2 MW)     | 52.0          | 17.6         |         |              |              |               |
|                          | Haripur (SBU 56 MW)        | 16.0          | 14.9         |         |              |              |               |
|                          | Haripur IPP 412 MW         | 60.0          | 47.8         |         |              |              |               |
|                          | Meghnaghat IPP 450 MW      | 75.0          | 66.6         |         |              |              |               |
|                          | Tongi (105 MW)             | 26.0          | 0.0          |         |              |              |               |
|                          | RPCL (197 MW)              | 40.0          | 30.3         |         |              |              |               |
|                          | Madhabdi 35 MW REB         | 9.0           | 7.0          |         |              |              |               |
|                          | Ashulia 45 MW REB          | 10.0          | 6.4          |         |              |              |               |
|                          | Tangail 22 MW SIPP         | 5.0           | 3.4          |         |              |              |               |
|                          | Narsingdi 22 MW SIPP       | 5.0           | 2.5          |         |              |              |               |
|                          | Maona 33 MW SIPP           | 8.0           | 5.9          |         |              |              |               |
|                          | Rupganj 33 MW SIPP         | 8.0           | 6.8          |         |              |              |               |
|                          | EGCB 335 MW                | 55.0          | 0.0          |         |              |              |               |
| Horipur 450 MW (EGCB)    | 75.0                       | 65.2          |              |         |              |              |               |
| Regent 150 MW            | 27.0                       | 15.9          |              |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>707.0</b>  | <b>427.8</b> |         | <b>104.0</b> | <b>42.0</b>  | <b>1257.6</b> |
|                          |                            |               |              |         |              |              | <b>1727.4</b> |
| BGDCL                    | Ashuganj 648 MW*           |               |              | AFCL    | 52.0         | 6.3          | 78.4          |
|                          | Ashuganj 55 MW rental      | 192.0         | 114.7        |         |              |              |               |
|                          | Ashuganj 53 MW rental      |               |              |         |              |              |               |
|                          | Ashuganj -80 MW Rent       | 20.0          | 0.0          |         |              |              |               |
|                          | Ashuganj 225MW             | 40.0          | 16.1         |         |              |              |               |
|                          | Ashuganj 200 MW Modular    | 40.0          | 13.6         |         |              |              |               |
|                          | APS 450 MW CCPP S          | 62.0          | 49.4         |         |              |              |               |
|                          | APS 450 MW CCPP N          | 62.0          | 0.0          |         |              |              |               |
|                          | B-baria 70 MW rental       | 18.0          | 4.3          |         |              |              |               |
|                          | Feni-22 MW SIPP            | 5.0           | 3.3          |         |              |              |               |
|                          | Mohipal-11 MW SIPP         | 3.0           | 2.0          |         |              |              |               |
|                          | Jangalia-33 MW SIPP        | 8.0           | 3.2          |         |              |              |               |
|                          | Chandpur 150 MW CCPP       | 27.0          | 4.9          |         |              |              |               |
| Cornilla REB 24 MW       | 6.0                        | 2.9           |              |         |              |              |               |
| Midland Power 51 MW      | 12.0                       | 3.5           |              |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>495.0</b>  | <b>217.9</b> |         | <b>52.0</b>  | <b>6.3</b>   | <b>78.4</b>   |
|                          |                            |               |              |         |              |              | <b>302.5</b>  |
| KGDCL                    | Rauzan (2x180) MW          | 95.0          | 0.0          | CUFL    | 52.0         | 46.5         | 0.0           |
|                          | Sikalbaha (40 MW)          | 12.0          | 0.0          | KAFCO   | 63.0         | 4.0          | 136.0         |
|                          | Sikalbaha (150 MW)         | 38.0          | 0.0          |         |              |              |               |
|                          | Barabkunda 22 MW SIPP      | 5.0           | 3.3          |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>150.0</b>  | <b>3.3</b>   |         | <b>115.0</b> | <b>50.6</b>  | <b>136.0</b>  |
|                          |                            |               |              |         |              |              | <b>189.9</b>  |
| JGTDSL                   | Shahjibazar 2x30 MW        | 18.0          | 17.2         | SFF     | 45.0         | 41.6         | 82.9          |
|                          | S.Bazar 3 yrs rental 50 MW | 12.0          | 5.3          |         |              |              |               |
|                          | S.Bazar 15 yrs rent 86 MW  | 20.0          | 7.8          |         |              |              |               |
|                          | S.Bazar 330 MW             | 47.0          | 26.1         |         |              |              |               |
|                          | Fenchuganj CC1 90 MW       | 17.0          | 17.0         |         |              |              |               |
|                          | Fenchuganj CC2 105 MW      | 18.0          | 17.5         |         |              |              |               |
|                          | Kumargaon 20 MW            | 2.0           | 0.0          |         |              |              |               |
|                          | K.gaon 3 yrs rent 50 MW    | 12.0          | 0.0          |         |              |              |               |
|                          | K.gaon 15 yrs rent 10 MW   | 3.0           | 1.7          |         |              |              |               |
|                          | K.gaon 142 MW CCPP         | 36.0          | 23.7         |         |              |              |               |
|                          | Habiganj 11 MW SIPP        | 3.0           | 2.3          |         |              |              |               |
|                          | F.ganj 15 yrs rent 51 MW   | 13.0          | 4.5          |         |              |              |               |
|                          | F.ganj 3 yrs rent 50 MW    | 10.0          | 7.0          |         |              |              |               |
| Shahjahanullah pgcl Rent | 5.0                        | 3.4           |              |         |              |              |               |
| Bibiyana-2 341 MW        | 50                         | 49.8          |              |         |              |              |               |
| Khushiara 163 MW         | 22                         | 16.1          |              |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>288.0</b>  | <b>199.4</b> |         | <b>45.0</b>  | <b>41.6</b>  | <b>82.9</b>   |
|                          |                            |               |              |         |              |              | <b>323.9</b>  |
| PGCL                     | Westmont 70 MW             |               | 0.0          |         |              |              |               |
|                          | Baghabari (100+71 MW)      | 50.0          | 0.0          |         |              |              | 21.958        |
|                          | Bogra 15 yrs rent (20 MW)  | 5.0           | 4.4          |         |              |              |               |
|                          | Ullapara 11 MW SIPP        | 3.0           | 1.5          |         |              |              |               |
|                          | Bogra 3 yrs rent (20 MW)   | 5.0           | 2.6          |         |              |              |               |
| North-West Power         | 38.0                       | 0.0           |              |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>101.0</b>  | <b>8.6</b>   |         | <b>0.0</b>   | <b>0.0</b>   | <b>22.0</b>   |
|                          |                            |               |              |         |              |              | <b>30.6</b>   |
| SGCL                     | Bhola 3 yrs rent 34.5 MW   | 10.0          |              |         |              |              |               |
|                          | Bhola 225 MW               | 35.0          | 30.4         |         |              |              |               |
|                          | Bheramara 360MW            | 55.0          | 25.97        |         |              |              |               |
|                          | <b>Sub-Total</b>           | <b>100.0</b>  | <b>56.4</b>  |         | <b>0.0</b>   | <b>0.0</b>   | <b>56.4</b>   |
|                          |                            |               |              |         |              |              | <b>56.4</b>   |
|                          | <b>Total :</b>             | <b>1841.0</b> | <b>913.3</b> |         | <b>316.0</b> | <b>140.5</b> | <b>1576.8</b> |
|                          |                            |               |              |         |              |              | <b>2630.6</b> |

## Non-grid power

|                             |               |              |  |              |              |               |
|-----------------------------|---------------|--------------|--|--------------|--------------|---------------|
| TGTDCCL                     | 70.5          |              |  |              |              |               |
| KGDCL                       | 10.6          |              |  |              |              |               |
| <b>Total Non-Grid Power</b> | <b>81.1</b>   |              |  |              |              | <b>81.1</b>   |
| <b>Grand Total</b>          | <b>1841.0</b> | <b>994.3</b> |  | <b>316.0</b> | <b>140.5</b> | <b>1576.8</b> |
| % of Total Distribution     |               | 36.7         |  | 5.2          | 58.1         | 100           |