

Petrobanqla
Production & Marketing Division
3, Kawran Bazar, Dhaka-1215

Date : 17-18 Dec, 2017

From 8.00 to 8.00

Units:

Gas in MMCFD
 Condensate/ NGL/ MS/ HSD in BBLD
 LPG in Kg

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Production Capacity | Production | | Pro.as a % of T.Cap(Gas) | Pro.as a % of T.Prod(Gas) |
|-----------|------------------------------|------------------------|---------------------|---------------|----------------|--------------------------|---------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFCCL | Titas | 26 | 542 | 532.3 | 490.0 | 19.3 | 20.8 |
| | Habiganj | 7 | 225 | 219.5 | 10.8 | 8.0 | 1.3 |
| | Bakhrabad | 6 | 43 | 32.8 | 18.0 | 1.2 | 1.1 |
| | Narsingdi | 2 | 30 | 27.0 | 45.3 | 1.0 | 1.1 |
| | Meghna | 1 | 11 | 12.7 | 21.5 | 0.5 | 0.5 |
| | Sub-Total | 42 | 851 | 824.3 | 585.6 | 29.9 | 32.2 |
| 2. SGFL | Sylhet | 2 | 8 | 4.7 | 31.9 | 0.2 | 0.2 |
| | Kailashitia #1 (Silicagel) | 2 | 13 | 9.4 | 55.9 | 0.3 | 0.4 |
| | Kailashitia #2 (MSTE) | 3 | 55 | 53.9 | 434.8 | 2.0 | 2.1 |
| | Rashidpur | 5 | 60 | 54.4 | 31.8 | 2.0 | 2.1 |
| | Beanibazar | 2 | 15 | 9.2 | 145.3 | 0.3 | 0.4 |
| | Sub-Total | 14 | 151 | 131.7 | 699.6 | 4.8 | 5.1 |
| 3. BAPEX | Salda | 1 | 10 | 3.5 | 0.7 | 0.1 | 0.1 |
| | Fenchuganj | 3 | 26 | 12.9 | 10.0 | 0.5 | 0.5 |
| | Shahbazpur | 3 | 50 | 38.3 | 6.0 | 1.4 | 1.5 |
| | Semutung | 2 | 3 | 1.0 | 0.7 | 0.0 | 0.0 |
| | Sundalpur | 0 | 0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | Srikail | 3 | 40 | 35.3 | 103.9 | 1.3 | 1.4 |
| | Begumganj | 0 | 0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Rupganj | 1 | 8 | 0.0 | 0.0 | 0.0 | 0.0 | |
| | Sub-Total | 13 | 137 | 91.0 | 121.2 | 3.3 | 3.6 |
| | Sub-Total (1+2+3) | 69 | 1139 | 1046.9 | 1406.3 | 38.0 | 40.9 |
| 4. IOCs | Jalalabad | 7 | 270 | 262.7 | 1126.1 | 9.5 | 10.3 |
| | CHEVRON | 5 | 42 | 31.8 | 5.0 | 1.2 | 1.2 |
| | Bibiyana | 26 | 1200 | 1127.9 | 8386.6 | 41.0 | 44.0 |
| | TULLOW | 5 | 103 | 93.0 | 286.0 | 3.4 | 3.6 |
| | Sub-Total | 43 | 1615 | 1515.5 | 9803.7 | 55.0 | 59.1 |
| | Grand Total (1+2+3+4) | 112 | 2754 | 2562.4 | 11210.1 | 93.0 | 100.0 |

III. RPGLCL Production

| Feed Received | | Production | | |
|---------------|-------|------------|-------|-------|
| NGL | Cond. | LPG | MS | HSD |
| 547.2 | 0.0 | 18351 | 870.6 | 277.6 |

N-S & RA pipeline
 Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 231.9 |
| AB2 | 230.1 |
| BB | 288.7 |
| VS3 | 118.7 |
| AM | 492.6 |
| BD | 310.4 |
| Total | 1672.4 |

Remarks:

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|--|----------------------------|--------------|------------|--------------|--------------|---------------|----------------------------------|
| | Demand | Supply | Company | Supply | | | |
| TGTDCCL | Ghorashal (598 MW)* | 148.0 | 41.7 | JFCL | 45.0 | 42.0 | 1235.6 |
| | Ghorashal-78 MW Rent | 20.0 | 15.0 | UFFL | 45.0 | 0.9 | |
| | Ghorashal-145 MW Rent | 38.0 | 29.6 | PUFF | 14.0 | 0.0 | |
| | Siddhirganj (190 MW) | 30.0 | 0.0 | | | | * GPS Unit 2,5,6 shutdown. |
| | Siddhirganj (105X2 MW) | 52.0 | 20.5 | | | | * Siddhirganj (190 MW) Shutdown. |
| | Haripur (SBU 56 MW) | 16.0 | 15.6 | | | | * Tongi (105 MW) Shutdown |
| | Haripur IPP 412 MW | 60.0 | 57.0 | | | | * UFFL, PUFF shutdown |
| | Meghnaghat IPP 450 MW | 75.0 | 66.8 | | | | |
| | Tongi (105 MW) | 26.0 | 0.0 | | | | |
| | RPCL (197 MW) | 40.0 | 29.4 | | | | |
| | Madhabdi 35 MW REB | 9.0 | 6.3 | | | | |
| | Ashulla 45 MW REB | 10.0 | 8.2 | | | | |
| | Tangail 22 MW SIPP | 5.0 | 3.4 | | | | |
| | Narsingdi 22 MW SIPP | 5.0 | 2.3 | | | | |
| | Maona 33 MW SIPP | 8.0 | 6.8 | | | | |
| | Rupganj 33 MW SIPP | 8.0 | 7.4 | | | | |
| | EGCB 335 MW | 55.0 | 35.9 | | | | |
| Horipur 450 MW (EGCB) | 75.0 | 63.0 | | | | | |
| Regent 150 MW | 27.0 | 17.4 | | | | | |
| Sub-Total | 707.0 | 426.1 | | 104.0 | 42.9 | 1235.6 | 1704.6 |
| BGDCL | Ashuganj 648 MW* | | 79.4 | AFCL | 52.0 | 6.3 | 77.6 |
| | Ashuganj 55 MW rental | 192.0 | | | | | |
| | Ashuganj 53 MW rental | | 0.0 | | | | |
| | Ashuganj -80 MW Rent | 20.0 | | | | | |
| | Ashuganj 225MW | 40.0 | 33.6 | | | | |
| | Ashuganj 200 MW Modular | 40.0 | 16.7 | | | | |
| | APS 450 MW CCPP S | 62.0 | 49.2 | | | | |
| | APS 450 MW CCPP N | 62.0 | 0.0 | | | | |
| | B-baria 70 MW rental | 18.0 | 4.5 | | | | |
| | Feni-22 MW SIPP | 5.0 | 3.4 | | | | |
| | Mohipal-11 MW SIPP | 3.0 | 2.1 | | | | |
| | Jangalia-33 MW SIPP | 8.0 | 4.7 | | | | |
| | Chandpur 150 MW CCPP | 27.0 | 14.7 | | | | |
| Cornilla REB 24 MW | 6.0 | 4.1 | | | | | |
| Midland Power 51 MW | 12.0 | 3.6 | | | | | |
| Sub-Total | 495.0 | 216.0 | | 52.0 | 6.3 | 77.6 | 299.9 |
| KGDCL | Rauzan (2x180) MW | 95.0 | 0.0 | CUFL | 52.0 | 46.3 | 0.0 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCO | 63.0 | 3.1 | 149.2 |
| | Sikalbaha (150 MW) | 38.0 | 0.0 | | | | |
| | Barakkunda 22 MW SIPP | 5.0 | 3.6 | | | | |
| Sub-Total | 150.0 | 3.6 | | 115.0 | 49.4 | 149.2 | 202.2 |
| JGTDLSL | Shahjibazar 2x30 MW | 18.0 | 17.1 | SFF | 45.0 | 42.5 | 83.6 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 3.6 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 7.0 | | | | |
| | S.Bazar 330 MW | 47.0 | 20.7 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 14.9 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 16.3 | | | | |
| | Kumargaon 20 MW | 2.0 | 0.0 | | | | |
| | K.gaoon 3 yrs rent 50 MW | 12.0 | 0.0 | | | | |
| | K.gaoon 15 yrs rent 10 MW | 3.0 | 1.7 | | | | |
| | K.gaoon 142 MW CCPP | 36.0 | 22.6 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 1.8 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 2.9 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 2.2 | | | | |
| | Shahjahanullah pgcl Rent | 5.0 | 4.5 | | | | |
| | Bibiyana-2 341 MW | 50 | 0.0 | | | | |
| Khushiyara 163 MW | 22 | 20.0 | | | | | |
| Sub-Total | 288.0 | 135.3 | | 45.0 | 42.5 | 83.6 | 261.4 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 22.687 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 4.3 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 1.3 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 2.4 | | | | |
| | North-West Power | 38.0 | 0.0 | | | | |
| Sub-Total | 101.0 | 7.9 | | 0.0 | | 22.7 | 30.6 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 38.3 | | | | |
| | Bhola 225 MW | 35.0 | | | | | |
| | Bheramara 360MW | 55.0 | 56.02 | | | | |
| Sub-Total | 100.0 | 94.3 | | 0.0 | | 0.0 | 94.3 |
| Total : | 1841.0 | 883.2 | | 316.0 | 141.1 | 1568.6 | 2593.0 |
| 1565 (Considering diversity factor 0.85) | | | | | | | |
| Non-grid power | | | | | | | |
| TGTDCCL | | 72.1 | | | | | |
| KGDCL | | 10.0 | | | | | |
| Total Non-Grid Power | | 82.2 | | | | | 82.2 |
| Grand Total | 1841.0 | 965.4 | | 316.0 | 141.1 | 1568.6 | 2675.1 |
| % of Total Distribution | | 36.1 | | | 5.3 | 58.8 | 100 |