

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Capacity | Production | | Pro. as a % of T.Cap.(Gas) | Pro. as a % of T. Prod.(Gas) |
|--------------------------|----------------------------|------------------------|----------|------------|------------|----------------------------|------------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFL | Tilas | 26 | 542 | 400.4 | 326.0 | 10.6 | 15.1 |
| | Habiganj | 8 | 225 | 144.9 | 6.7 | 3.9 | 1.3 |
| | Bakhrabad | 7 | 43 | 34.3 | 36.5 | 0.9 | 1.0 |
| | Narsingdi | 2 | 30 | 26.3 | 42.0 | 0.7 | 1.0 |
| | Meghna | 1 | 11 | 3.2 | 3.9 | 0.1 | 0.1 |
| Sub-Total | | 44 | 851 | 609.1 | 415.1 | 16.2 | 23.0 |
| 2. SGFL | Sylhet | 1 | 6 | 5.2 | 33.2 | 0.1 | 0.2 |
| | Kailashtila #1 (Silicagel) | 1 | 13 | 4.1 | 19.2 | 0.1 | 0.2 |
| | Kailashtila #2 (MSTE) | 3 | 55 | 30.3 | 404.7 | 0.8 | 1.1 |
| | Rashidpur | 5 | 60 | 43.5 | 38.0 | 1.2 | 1.6 |
| | Beanibazar | 1 | 15 | 6.9 | 91.0 | 0.2 | 0.3 |
| Sub-Total | | 11 | 149 | 90.1 | 586.1 | 2.4 | 3.4 |
| 3. BAPEX | Salda | 2 | 3 | 4.1 | 1.9 | 0.1 | 0.2 |
| | Fenchuganj | 2 | 26 | 14.2 | 6.8 | 0.4 | 0.5 |
| | Shahbazpur | 4 | 50 | 62.9 | 7.4 | 1.7 | 2.4 |
| | Semutang | 2 | 3 | 0.6 | 0.0 | 0.0 | 0.0 |
| | Sundalpur | 1 | 5 | 7.9 | 0.5 | 0.2 | 0.3 |
| | Srikail | 3 | 40 | 42.5 | 175.5 | 1.1 | 1.6 |
| | Begumganj | 1 | 10 | 8.1 | 2.7 | 0.2 | 0.3 |
| Rupganj | 0 | 8 | 0.0 | 0.0 | 0.0 | 0.0 | |
| Sub-Total | | 15 | 145 | 140.2 | 194.8 | 3.7 | 5.3 |
| Sub-Total (1+2+3) | | 70 | 1145 | 839.4 | 1195.9 | 22.3 | 31.7 |
| 4. IOCs | Jalalabad | 7 | 270 | 180.8 | 766.9 | 4.8 | 6.8 |
| | CHEVRON | 5 | 42 | 17.5 | 1.7 | 0.5 | 0.7 |
| | Bibiyan | 26 | 1200 | 1179.5 | 4388.3 | 31.4 | 44.5 |
| | TULLOW | 5 | 103 | 49.1 | 140.0 | 1.3 | 1.9 |
| Sub-Total | | 43 | 1615 | 1426.9 | 5296.9 | 37.9 | 53.9 |
| 5. RPGCL (R-LNG) | | | 1000 | 381.4 | | 10.1 | 14.4 |
| | Sub-Total | | 0 | 1000 | 381.4 | 0.0 | 10.1 |
| Grand Total (1+2+3+4+5): | | 113 | 3760 | 2647.8 | 6492.8 | 70.4 | 100.0 |

III. RPGCL Production

| Feed Received | | Production | | |
|---------------|-------|------------|-----|-----|
| NGL | Cond. | LPG | MS | HSD |
| 0.0 | 0.0 | 0 | 0.0 | 0.0 |

N-S & RA pipeline
 Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 0.0 |
| AB2 | 106.4 |
| BB | 273.4 |
| VS3 | 118.4 |
| AM | 297.1 |
| BD | 466.4 |
| Total | 1261.7 |

Remarks:

* RPGCL Shutdown.

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|-------------------------------------|-----------------------------|--------|------------|------------|--------------|-------|---------|
| | Demand | Supply | Company | Max.Demand | | | |
| TGTDCL | Ghorashal (1315 MW) | 148.0 | 32.7 | JFCL | 45.0 | 2.9 | 1059.0 |
| | Max (G)-78 MW Rent | 20.0 | 0.0 | UFFL | 45.0 | 0.0 | |
| | Aggreko (GSL)-145 MW Rent | 38.0 | 0.0 | PUFFL | 14.0 | 0.0 | |
| | Siddhirganj (210 MW) | 30.0 | 0.0 | | | | |
| | Siddhirganj (2x120 MW) | 52.0 | 0.0 | | | | |
| | HPS (100 MW) | 16.0 | 0.0 | | | | |
| | HPS(EGCB) 412 MW | 68.0 | 60.6 | | | | |
| | Meghnaghat IPP 450 MW | 75.0 | 37.5 | | | | |
| | Summit Meghn. 335 MW | 55.0 | 0.0 | | | | |
| | Tongi (80 MW) | 26.0 | 0.0 | | | | |
| | RPCL (210 MW) | 40.0 | 18.3 | | | | |
| | Madhabdi (27+10 MW) REB | 9.0 | 6.6 | | | | |
| | Ashulia (24+10 MW) REB | 10.0 | 7.4 | | | | |
| | Doreen Tangail 22 MW SIPP | 5.0 | 2.6 | | | | |
| | Doreen Narsingdi 22 MW SIPP | 5.0 | 3.7 | | | | |
| | Maona 33 MW SIPP | 8.0 | 7.1 | | | | |
| Rupganj 33 MW SIPP | 8.0 | 6.1 | | | | | |
| EGCB Siddhirganj 335 MW | 55.0 | 50.5 | | | | | |
| HPL (360 MW) | 55.0 | 49.1 | | | | | |
| Regent 108 MW | 27.0 | 19.2 | | | | | |
| Sub-Total | | 750.0 | 301.6 | | 104.0 | 2.9 | 1059.0 |
| BGDCL | Ashuganj 648 MW* | | | AFCL | 52.0 | 46.6 | 79.3 |
| | Ashuganj 55 MW rental | 192.0 | 7.0 | | | | 10.6 |
| | Ashuganj 53 MW rental | | | | | | |
| | Ashuganj -80 MW Rent | 20.0 | 0.0 | | | | |
| | Ashuganj 225MW | 40.0 | 32.4 | | | | |
| | Ashuganj 200 MW Modular | 40.0 | 1.9 | | | | |
| | APS 450 MW CCPP S | 62.0 | 42.8 | | | | |
| | APS 450 MW CCPP N | 62.0 | 46.0 | | | | |
| | B-baria 70 MW rental | 24.0 | 0.0 | | | | |
| | Feni-22 MW SIPP | 5.0 | 4.6 | | | | |
| | Mohipal-11 MW SIPP | 3.0 | 2.0 | | | | |
| | Jangalia-33 MW SIPP | 8.0 | 4.9 | | | | |
| Chandpur 150 MW CCPP | 27.0 | 19.6 | | | | | |
| Comilla REB 24 MW | 6.0 | 4.4 | | | | | |
| Midland Power 51 MW | 12.0 | 9.8 | | | | | |
| Sub-Total | | 501.0 | 175.6 | | 52.0 | 46.6 | 89.9 |
| KGDCL | Raozan (2x210) MW | 95.0 | 0.0 | CUFL | 52.0 | 9.1 | 147.2 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCCO | 63.0 | 0.0 | 0.0 |
| | Sikalbaha (225+150+65) MW | 73.0 | 38.1 | | | | |
| | Barakkunda 22 MW SIPP | 5.0 | 2.6 | | | | |
| Sub-Total | | 185.0 | 40.9 | | 115.0 | 9.1 | 147.2 |
| JGTDSL | Shahjibazar 2x30 MW | 18.0 | 18.6 | SFCL | 45.0 | 41.6 | 95.2 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 0.0 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 7.0 | | | | |
| | S.Bazar 330 MW | 47.0 | 0.0 | | | | |
| | S.Bazar 100 MW | 18.0 | 0.0 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 9.2 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 9.1 | | | | |
| | Kumargaon 20 MW | 2.0 | 4.2 | | | | |
| | K.gaoon 3 yrs rent 50 MW | 12.0 | 0.6 | | | | |
| | K.gaoon 15 yrs rent 10 MW | 3.0 | 2.4 | | | | |
| | K.gaoon 142 MW CCPP | 36.0 | 31.8 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 1.7 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 0.4 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 0.4 | | | | |
| | Shahjahanullah pgl Rent | 5.0 | 0.0 | | | | |
| | Bibiyan-2 341 MW | 50 | 47.1 | | | | |
| | Bibiyan-3 400 MW | 40 | 61.2 | | | | |
| Bibiyan-S,400 MW,PDB | 43 | 59.3 | | | | | |
| Khushiyara 163 MW | 28 | 0.0 | | | | | |
| Sub-Total | | 395.0 | 252.9 | | 45.0 | 41.6 | 95.2 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 26.0 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 4.6 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 2.2 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | NWPGCL Unit -1 | 38.0 | 31.6 | | | | |
| | NWPGCL Unit -2 | 38.0 | 0.0 | | | | |
| | NWPGCL Unit -3 | 38.0 | 27.5 | | | | |
| NWPGCL Unit -4 | 70.0 | 50.3 | | | | | |
| Sub-Total | | 247.0 | 116.2 | | 0.0 | | 26.0 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 8.2 | | | | 4.5 |
| | Bhola 225 MW | 35.0 | 17.3 | | | | |
| | Bheramara 360MW | 65.0 | 39.0 | | | | |
| | Aggreko 95MW | 26.0 | 0.0 | | | | |
| | NBBL 220MW | 38.0 | 32.7 | | | | |
| Sub-Total | | 174.0 | 97.2 | | 0.0 | | 4.5 |
| Total : | | 2252.0 | 984.4 | | 316.0 | 100.1 | 1421.8 |
| (Considering diversity factor 0.85) | | 1914 | | | 269 | | 2506.3 |

Non-grid power

| | |
|-------------------------|---------------|
| TGTDCL | 66.4 |
| KGDCL | 9.4 |
| Total Non-Grid Power | 75.8 |
| Grand Total | 2252.0 |
| % of Total Distribution | 41% |