

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Capacity | Production | | Pro. as a % of T.Cap.(Gas) | Pro. as a % of T. Prod.(Gas) |
|-----------------|--------------------------------|------------------------|-------------|---------------|---------------|----------------------------|------------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFL | Tilas | 26 | 542 | 402.5 | 317.0 | 10.7 | 14.0 |
| | Habiganj | 8 | 225 | 156.0 | 10.3 | 4.1 | 1.2 |
| | Bakhrabad | 7 | 43 | 35.5 | 43.0 | 0.9 | 0.9 |
| | Narsingdi | 2 | 30 | 27.1 | 43.0 | 0.7 | 0.9 |
| | Meghna | 1 | 11 | 7.6 | 14.3 | 0.2 | 0.3 |
| | Sub-Total | 44 | 851 | 628.7 | 427.6 | 16.7 | 21.8 |
| 2. SGFL | Sylhet | 1 | 6 | 6.4 | 39.6 | 0.2 | 0.2 |
| | Kailashtila #1 (Silicagel) | 1 | 13 | 4.1 | 21.8 | 0.1 | 0.1 |
| | Kailashtila #2 (MSTE) | 3 | 55 | 25.0 | 320.5 | 0.7 | 0.9 |
| | Rashidpur | 5 | 60 | 44.4 | 38.8 | 1.2 | 1.5 |
| | Beanibazar | 1 | 15 | 7.3 | 104.1 | 0.2 | 0.3 |
| | Sub-Total | 11 | 149 | 87.1 | 524.9 | 2.3 | 3.0 |
| 3. BAPEX | Salda | 2 | 3 | 2.4 | 0.0 | 0.1 | 0.1 |
| | Fenchuganj | 2 | 26 | 20.7 | 12.6 | 0.6 | 0.7 |
| | Shahbazpur | 4 | 50 | 63.9 | 7.7 | 1.7 | 2.2 |
| | Semutang | 2 | 3 | 0.8 | 0.0 | 0.0 | 0.0 |
| | Sundalpur | 1 | 5 | 7.3 | 0.5 | 0.2 | 0.3 |
| | Srikail | 3 | 40 | 44.2 | 184.6 | 1.2 | 1.5 |
| | Begumganj | 1 | 10 | 8.2 | 2.9 | 0.2 | 0.3 |
| | Rupganj | 0 | 8 | 0.0 | 0.0 | 0.0 | 0.0 |
| | Sub-Total | 15 | 145 | 147.6 | 208.3 | 3.9 | 5.1 |
| | Sub-Total (1+2+3) | 70 | 1145 | 863.4 | 1160.7 | 23.0 | 30.0 |
| 4. IOCs | Jalalabad | 7 | 270 | 184.5 | 914.8 | 4.9 | 6.4 |
| | CHEVRON | 5 | 42 | 14.4 | 3.0 | 0.4 | 0.5 |
| | Bibiyana | 26 | 1200 | 1199.9 | 4538.9 | 31.9 | 41.6 |
| | TULLOW | 5 | 103 | 49.2 | 151.0 | 1.3 | 1.7 |
| | Sub-Total | 43 | 1615 | 1448.0 | 5607.7 | 38.5 | 50.2 |
| 5. RPGL (R-LNG) | | | 1000 | 571.0 | | 15.2 | 19.8 |
| | Sub-Total | 0 | 1000 | 571.0 | 0.0 | 15.2 | 19.8 |
| | Grand Total (1+2+3+4+5) | 113 | 3760 | 2882.4 | 6768.4 | 76.7 | 100.0 |

III. RPGL Production

| Feed Received | | Production | | |
|---------------|-------|------------|-----|-----|
| NGL | Cond. | LPG | MS | HSD |
| 0.0 | 0.0 | 0 | 0.0 | 0.0 |

N-S & RA pipeline
Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 0.0 |
| AB2 | 0.0 |
| BB | 318.5 |
| VS3 | 107.6 |
| AM | 485.0 |
| BD | 429.8 |
| Total | 1340.9 |

Remarks:

* RPGL Shutdown.

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|-------------------------------------|-----------------------------|--------------|------------|--------------|--------------|---------------|---------------|
| | Demand | Supply | Company | Max.Demand | | | |
| TGTDCL | Ghorashal (1315 MW) | 148.0 | 51.6 | JFCL | 45.0 | 44.1 | 1357.5 |
| | Max (G)-78 MW Rent | 20.0 | 0.0 | UFFL | 45.0 | 0.0 | |
| | Aggreko (GSL)-145 MW Rent | 38.0 | 0.0 | PUFFL | 14.0 | 0.0 | |
| | Siddhirganj (210 MW) | 30.0 | 0.0 | | | | |
| | Siddhirganj (2x120 MW) | 52.0 | 0.0 | | | | |
| | HPS (100 MW) | 16.0 | 0.0 | | | | |
| | HPS(EGCB) 412 MW | 68.0 | 0.0 | | | | |
| | Meghnaghat IPP 450 MW | 75.0 | 45.2 | | | | |
| | Summit Meghn. 335 MW | 55.0 | 46.7 | | | | |
| | Tongi (80 MW) | 26.0 | 0.0 | | | | |
| | RPCL (210 MW) | 40.0 | 24.7 | | | | |
| | Madhabdi (27+10 MW) REB | 9.0 | 5.8 | | | | |
| | Ashulia (24+10 MW) REB | 10.0 | 8.0 | | | | |
| | Doreen Tangail 22 MW SIPP | 5.0 | 3.6 | | | | |
| | Doreen Narsingdi 22 MW SIPP | 5.0 | 4.5 | | | | |
| | Maona 33 MW SIPP | 8.0 | 6.1 | | | | |
| Rupganj 33 MW SIPP | 8.0 | 7.5 | | | | | |
| EGCB Siddhirganj 335 MW | 55.0 | 31.6 | | | | | |
| HPL (360 MW) | 55.0 | 0.0 | | | | | |
| Regent 108 MW | 27.0 | 23.2 | | | | | |
| Sub-Total | 750.0 | 258.5 | | 104.0 | 44.1 | 1357.5 | |
| BGDCL | Ashuganj 648 MW* | | | AFCL | 52.0 | 41.2 | 89.2 |
| | Ashuganj 55 MW rental | 192.0 | 12.6 | | | | 12.5 |
| | Ashuganj 53 MW rental | | | | | | |
| | Ashuganj -80 MW Rent | 20.0 | 0.0 | | | | |
| | Ashuganj 225MW | 40.0 | 35.2 | | | | |
| | Ashuganj 200 MW Modular | 40.0 | 7.2 | | | | |
| | APS 450 MW CAPP S | 62.0 | 45.8 | | | | |
| | APS 450 MW CAPP N | 62.0 | 45.2 | | | | |
| | B-baria 70 MW rental | 24.0 | 0.0 | | | | |
| | Feni-22 MW SIPP | 5.0 | 4.5 | | | | |
| | Mohipal-11 MW SIPP | 3.0 | 2.0 | | | | |
| | Jangalia-33 MW SIPP | 8.0 | 4.9 | | | | |
| | Chandpur 150 MW CAPP | 27.0 | 4.9 | | | | |
| Comilla REB 24 MW | 6.0 | 4.0 | | | | | |
| Midland Power 51 MW | 12.0 | 9.8 | | | | | |
| Sub-Total | 501.0 | 176.1 | | 52.0 | 41.2 | 101.7 | 319.0 |
| KGDCL | Raozan (2x210) MW | 95.0 | 0.0 | CUFL | 52.0 | 41.0 | 190.7 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCO | 63.0 | 46.4 | 0.0 |
| | Sikalbaha (225+150+65) MW | 73.0 | 0.0 | | | | |
| | Barabkunda 22 MW SIPP | 5.0 | 0.0 | | | | |
| Sub-Total | 185.0 | 0.0 | | 115.0 | 87.4 | 190.7 | 278.1 |
| JGTDSL | Shahjibazar 2x30 MW | 18.0 | 17.7 | SFCL | 45.0 | 42.0 | 82.4 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 0.0 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 18.9 | | | | |
| | S.Bazar 330 MW | 47.0 | 46.4 | | | | |
| | S.Bazar 100 MW | 18.0 | 0.0 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 0.0 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 8.4 | | | | |
| | Kumargaon 20 MW | 2.0 | 0.0 | | | | |
| | K.gaon 3 yrs rent 50 MW | 12.0 | 0.0 | | | | |
| | K.gaon 15 yrs rent 10 MW | 3.0 | 2.4 | | | | |
| | K gaon 142 MW CAPP | 36.0 | 0.0 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 2.3 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 10.4 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 0.0 | | | | |
| | Shahjahanullah pgl Rent | 5.0 | 4.7 | | | | |
| | Bibiyana-2 341 MW | 50 | 47.6 | | | | |
| | Bibiyana-3 400 MW | 40 | 60.2 | | | | |
| Bibiyana-S,400 MW,PDB | 43 | 0.0 | | | | | |
| Khushiyara 163 MW | 28 | 0.0 | | | | | |
| Sub-Total | 395.0 | 219.0 | | 45.0 | 42.0 | 82.4 | 343.4 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 30.2 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 4.6 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 1.6 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | NWPGCL Unit -1 | 38.0 | 0.0 | | | | |
| | NWPGCL Unit -2 | 38.0 | 32.5 | | | | |
| NWPGCL Unit -3 | 38.0 | 32.9 | | | | | |
| NWPGCL Unit -4 | 70.0 | 0.0 | | | | | |
| Sub-Total | 247.0 | 71.6 | | 0.0 | | 30.2 | 101.9 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 5.9 | | | | 4.2 |
| | Bhola 225 MW | 35.0 | 17.4 | | | | |
| | Bheramara 360MW | 65.0 | 55.5 | | | | |
| | Aggreko 95MW | 26.0 | 3.1 | | | | |
| NBBL 220MW | 38.0 | 33.3 | | | | | |
| Sub-Total | 174.0 | 115.1 | | 0.0 | | 4.2 | 119.3 |
| Total | 2252.0 | 840.3 | | 316.0 | 214.8 | 1766.7 | 2821.8 |
| (Considering diversity factor 0.85) | | 1914 | | 269 | | | |

Non-grid power

| | |
|-----------------------------|---------------|
| TGTDCL | 93.8 |
| KGDCL | 8.9 |
| Total Non-Grid Power | 102.7 |
| Grand Total | 2252.0 |
| % of Total Distribution | 3.2% |